

STATE OF IDAHO
DEPARTMENT OF LANDS



POLYPROPYLENE TANKS – COEUR D’ALENE
REQUEST FOR QUOTE NO. 26-3159
DUE BEFORE 2:00:00 PM PT ON DECEMBER 4th, 2025

REQUEST FOR QUOTE AND INSTRUCTIONS

Quotes will be received by the Idaho Department of Lands for the following:

POLYPROPYLENE TANKS – COEUR D’ALENE

DELIVERY LOCATION:

Idaho Department of Lands
3328 W. Industrial Loop
Coeur D’Alene, ID 83815

INSTRUCTIONS

All price quotes must be entered on the attached Schedule A. The signed Schedule A must be submitted with your response. No more than one award will be made. A vendor **MUST** provide a price for each respective line to be considered for a purchase award. The submitting Vendor agrees that its Quotation shall be good and may not be withdrawn for a period of ninety (90) days after the scheduled closing date, unless otherwise identified in the Solicitation. No Quotation will be accepted if marked "price prevailing at time of delivery," "estimated prices," "actual costs to be billed," or similar phrases. After the date and time of closing, no price change will be allowed, unless otherwise stated in the Solicitation. The right is reserved to accept a quote on each item separately, or as a whole. IDL may award Purchase Order(s) in its best interest to the qualified Supplier submitting the lowest responsible and responsive quote, either by line item or in whole. IDL shall award the Purchase Order to the qualified Supplier submitting the lowest responsible and responsive quote.

- *Note: Specifications for tanks have been stated in the Schedule A. **THESE ARE EXACT PRODUCT SPECIFICATIONS** to ensure consistency in inventory/deployment. IDL reserves the right to **rescind an entire award** if item deviates from the specification listed.*
- *Idaho Department of Lands reserves the right to enter negotiations in accordance with IDL Procurement Policy #455.*

QUOTES DEADLINE AND DELIVERY REQUIREMENTS

Quotes must be received, and time stamped by the Idaho Department of Lands at the electronic address listed below **before 2:00:00 PM PT. on December 4th, 2025**. The Idaho Department of Lands is not responsible for delayed delivery of electronically submitted quotes. The date and time of electronically received quotes, to the Idaho Department of Lands email address listed below, will be used to determine if electronically submitted quotes were received by the due date and time specified. **Late Quotes will not be accepted. Mailed or Fax Quotes will not be accepted.**

Quote Email Address:

mrsande@idl.idaho.gov.

Emailed quotes are to be marked in the subject line with the following information: RFQ 26-3159 PolyPropylene Tanks

QUESTIONS

Questions pertaining to this RFQ must be submitted in writing by email to mrsande@idl.idaho.gov. The deadline for receiving questions is 12:00 PM PT, on 11/25/2025. Responses to all questions received will be posted as an addendum on the IDL website at www.idl.idaho.gov. Verbal questions will not be accepted.

SCHEDULE A

STATE OF IDAHO
DEPARTMENT OF LANDS
REQUEST FOR QUOTE
THIS IS NOT AN ORDER

Solicitation Number: 26-3159

Date: _____

INSTRUCTIONS:

Vendors must use this form in submitting prices.

Unit and total prices must be fully-burdened to include delivery to the stated location.

QUAN	UNIT	ARTICLES	UNIT PRICE	TOTAL PRICE						
4	Each	500 Gallon Polypropylene Tank for Type 5 Engine per following specifications: see attached FOB Destination: 3328 W. Industrial Loop Coeur d'Alene, ID 83815	\$ _____							
<table border="1"> <thead> <tr> <th>Action</th> <th>Due Date</th> </tr> </thead> <tbody> <tr> <td><i>Request for Quote Responses Due Before:</i></td> <td align="center"><i>2:00:00 P.T., 12/4/2025</i></td> </tr> <tr> <td><i>Delivery Requested by:</i></td> <td align="center"><i>2/16/2025</i></td> </tr> </tbody> </table>			Action	Due Date	<i>Request for Quote Responses Due Before:</i>	<i>2:00:00 P.T., 12/4/2025</i>	<i>Delivery Requested by:</i>	<i>2/16/2025</i>		
Action	Due Date									
<i>Request for Quote Responses Due Before:</i>	<i>2:00:00 P.T., 12/4/2025</i>									
<i>Delivery Requested by:</i>	<i>2/16/2025</i>									
Delivery requested <u>per</u> specifications EMAIL QUOTE TO: mrsande@idl.idaho.gov		We have stated hereon the prices at which we will furnish and at destination named above, the articles or services as specified. Delivery will be made as specified above. Firm _____ Street _____ City State Zip Code _____ Phone Fax _____ E-Mail _____ Taxpayer ID# _____ Signed by _____ Printed Name _____ Title _____								

All purchase orders related to this solicitation will be awarded in LUMA.

You must be registered in PaymentWorks & LUMA to receive a purchase order.

TANK SPECIFICATIONS

500 Gallon

Approximately-

- 76" Long
- 53" Wide
- 34" Tall
- 80" Overall Length

Tank Construction:

Tank to be constructed of polypropylene; baffled lengthways and crossways; top reinforced to accommodate loads; top must be removable to allow for tank cleanout; flanges front and rear of bottom outside of tank for mounting purposes. Flanges on top edges of tank for mounting a spare tire and carrier. Anti-cavitation dome inside of tank at suction fitting to allow water in tank to be drawn down to within one inch of bottom of tank.

Fittings:

Fittings must be of stainless-steel composition.

1. For suction side of pump, 2" NPT female. Location- center of fitting is 4 ½" from the right side of the tank and 3" from the bottom.
2. For transducer, ¼" NPT female. Location- center of fitting 11 ¾" from the right side of the tank and 3" from the bottom.
3. For discharge side of pump, 1 ½" NPT female. Location- center of fitting is 26 ¾" from the right side of the tank and 3" from the bottom.
4. For foam tank, ¾" NPT female. Location- bottom right corner of foam tank to discharge through rear of main tank.

Fill Spout:

Top of tank, as close the right rear corner as possible, minimum 6" with cap and removable screen.

Tank Gauge:

Right rear corner of tank to be constructed of clear material for observing water level in tank.

Foam Tank:

Inside main tank at left rear, 10-gallon capacity, fill spout on top of tank, as close the left rear corner as possible, 6" with cap.

Tank to fit in bed of service body with load space width of 54"

